

# TriaVent SMO-ALU

Varenr. ISOSMO\*

BV-certifikat 13125/D0 MED, udløbsdato: 13.01.2023. MED 2014/90/ EU.



## Lydskema

D <sub>i</sub> (mm)	L (mtr)	Attenuation, dB - Mid-frequency, Hz					
		125	250	500	1000	2000	4000
82	1	16	25	34	38	30	20
	2	22	37	48	54	46	30
	3	30	43	41	43	55	43
102	1	11	25	31	36	23	15
	2	17	31	51	50	38	26
	3	20	44	51	52	51	33
127	1	11	19	23	27	25	19
	2	17	31	43	43	35	22
	3	21	40	45	48	47	27
160	1	15	26	22	27	18	13
	2	22	38	35	39	29	20
	3	33	43	39	43	39	27
203	1	6	13	15	18	11	10
	2	15	31	32	38	21	18
	3	16	36	40	42	28	24
254	1	9	11	12	10	7	11
	2	21	24	24	22	13	15
	3	29	33	31	30	19	24
315	1	8	8	8	7	6	8
	2	16	15	14	13	9	13
	3	23	23	21	19	12	17
457	1	8	8	6	6	5	7
	2	18	15	14	12	8	10
	3	24	21	20	18	11	15
508	1	7	8	7	7	6	7
	2	-	-	-	-	-	-
	3	-	-	-	-	-	-

## Tryktabstabel

Alle værdier målt fuldt udstrakt og lige

### PRESSURE LOSS (STRAIGHT DUCT)

